



**Intertek Testing Services**  
ETL SEMKO

## EC TYPE EXAMINATION CERTIFICATE

Certificate Number EC 303

This is to certify that samples representative of production of the appliances listed below have been examined and found to comply with the essential requirements listed in Annex I of Council Directive of 29 June 1990 on the approximation of the laws of the Member States relating to appliances burning gaseous fuels (90/396/EEC).

*Certificate type:* Original  
*Original or Supplementary*

*Report Number:* 02007374

*Appliance type:* Ball valves

*Appliance names:* Art 45 "Export" Type (1/4" to 2" sizes in range)

*Product Identification No.* 359BN303

*Manufactured by:* IVR Valvole A Sfera S.P.A  
Via Risorgimento, 9 – Fraz. Ara  
28075 Grignasco (NO)  
Italy

*Scope:* At temperatures between -20°C and 60°C on all 2<sup>nd</sup> and 3<sup>rd</sup> family gas categories at inlet pressures up to and not exceeding 20 bar

**ITS Testing & Certification Ltd**  
Notified Body 0359

C. Davey  
Certifying Officer  
24 July 2002

*Issue date:*

**ITS Testing & Certification Ltd**  
ITS House, Cleeve Road, Leatherhead, Surrey KT22 7SB  
Tel: +44 (0)1372 370900 Fax: +44 (0)1372 370999  
<http://www.etlsemko.com/uk>

Registered No. 3272281 Registered office: 25 Savile Row, London W1X 1AA